



Water Quality Chemistry Services Lead School Testing Report Date: 5/5/17

San Diego Unified School District **Twain High**

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1168562	04/26/17	06:05 AM	SAMPLE 1	3710020-BBF-A	< 5	ug/L
W1168563	04/26/17	06:10 AM	SAMPLE 2	3710020-BBF-B	< 5	ug/L
W1168564	04/26/17	06:13 AM	SAMPLE 3	3710020-BBF-C	< 5	ug/L
W1168565	04/26/17	06:16 AM	SAMPLE 4	3710020-BBF-D	< 5	ug/L
W1168566	04/26/17	05:58 AM	SAMPLE 5	3710020-BBF-E	< 5	ug/L

Source	Source Description
SAMPLE 1	BLDG 6, Exterior wall near RM 6, lower left bubbler
SAMPLE 2	Room 5, bubbler at sink
SAMPLE 3	Room 4, bubbler at sink
SAMPLE 4	Room 3, bubbler at sink
SAMPLE 5	BLDG 7-13, exterior west wall, lower left bubbler

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L Action Level (AL) = 15 ug/L $\,$

Doug Campbell, Senior Chemist